



Ref. Certif. No.

GB959W Issue 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEME

SYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE**CERTIFICAT D'ESSAI OC**

Product
Produit

Emergency Luminaires

Name and address of the applicant
Nom et adresse du demandeur

Awex Spółka z o.o. Spółka komandytowa
Masłomiaça, Długa 39
32-091 MICHAŁOWICE
Poland

Name and address of the manufacturer
Nom et adresse du fabricant

As above

Name and address of the factory
Nom et adresse de l'usine

As above

*Note: When more than one factory, please report on page 2
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2^{ème} page*

Ratings and principal characteristics
Valeurs nominales et caractéristiques principales

Input 220-240V 50/60 Hz Class II, EXIT, EXIT P IP65

Trademark (if any)
Marque de fabrique (si elle existe)

AWEX

Model / Type Ref.
Ref. De type

See pages 2 and 3

Additional information (if necessary may also be reported
on page 2)
Les informations complémentaires (si nécessaire, peuvent
être indiqués sur la 2^{ème} page

See pages 2 and 3

A sample of the product was tested and found
to be in conformity with
Un échantillon de ce produit a été essayé et a été
considéré conforme à la

PUBLICATION	EDITION
IEC 60598-1:2014	8 th
IEC 60598-2-22:2014	4 th

As shown in the Test Report Ref. No. which forms part of
this Certificate
Comme indiqué dans le Rapport d'essais numéro de
référence qui constitue partie de ce Certificat

Report number: 8440725

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**

BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 05 September 2016

Original Issue date 10 August 2016

Signature:

Mark Littlejohns Certification Manager



Ref. Certif. No.

GB959W Issue 2

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC

CB TEST CERTIFICATE

CERTIFICAT D'ESSAI OC

The type references covered by this certificate are as listed below:

Model ref.	Power	Light source/ emergency module code	Duration	Mode	Option	Cover code or color	Assembly type
------------	-------	--	----------	------	--------	---------------------------	------------------

Self-contained

EXIT ETE	1W 2W 3W	LED / B	1/2/3 Hrs	Non- maintained (SE) Maintained (SA)	X/PT/AT/ RU	WH/GR/BL	Wall surface Exit sign / Emergency Luminaire
EXIT P ETPE	1W 2W 3W	LED / B	1/2/3 Hrs	Non- maintained (SE) Maintained (SA)	X/PT/AT/ RU	WH/GR/BL	Ceiling surface/ recessed. Exit sign

Central battery

EXIT ETE	1W 2W 3W	LED / F/ Z	Dependen t on Power system	Central Battery (CB)	CBS/ADS/ ADP	WH/GR/BL	Wall surface Exit sign / Emergency Luminaire
EXIT P ETPE	1W 2W 3W	LED / F/ Z	Dependen t on Power system	Central Battery (CB)	CBS/ADS/ ADP	WH/GR/BL	Ceiling surface/ recessed. Exit sign

This CB Test Certificate is issued by the National Certification Body
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000Date: 05 September 2016
Original Issue date 10 August 2016

Signature:

Mark Littlejohns Certification Manager



Ref. Certif. No.

GB959W

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE CERTIFICATS
D'ESSAIS DES EQUIPEMENTS ELECTRIQUES (IECEE)
METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**

The type references covered by this certificate are as listed below:

FZLV- central Power System

Model ref.	Power	Light source	Duration	Mode	Option	Cover code or color	Assembly type
EXIT ETE	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WH/GR/BL	Wall surface Exit sign / Emergency Luminaire
EXIT P ETPE	1W 2W 3W	LED	Dependent on Power system	Central Power System (FZLV)	NA	WH/GR/BL	Ceiling surface/ recessed. Exit sign

Legend

ETE – fixture EXIT

AT – Autotest

RU – rubic system UNA

B – code of emergency module (Uniled BM)

Z – code of electronic control gear (Uniled ADP)

ADP – central battery with electronic control gear
Uniled ADP

CBS – central battery system

ETPE – fixture EXIT P

PT – test button

N A – not applicable

F – code of electronic control gear (Uniled HDP)

X – without option

ADS – central battery with address module ADS20

WH – white, GR – gray, BL- black

Also tested to the requirements of BS EN 60598-1:2015 and BS EN 60598-2-22:2014.

Considered to the requirements for European group differences.

This CB Test Certificate is issued by the National Certification Body

Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**BSI, Kitemark Court,
Davy Avenue, Milton Keynes,
MK5 8PP. United Kingdom.
Phone +44 (0)8450 809000

Date: 05 September 2016

Original Issue date 10 August 2016

Signature:

Mark Littlejohns Certification Manager